




Industrie Service

**Przedsiębiorstwo Skoplast S. i K.
 Szkopek sp. Jawna
 Kaczory ul. Raszkowska 9A
 63-430 ODOLANOW
 POLAND**

The above organization is hereby entitled, on the basis of certificate No. 20 07 90319 001 and the appendant test reports, to affix the certification body's certification mark shown below to the following product (see description below).



Requirement:

The product fulfils the requirements for PE 100-RC pipes for alternative installation methods in keeping with the withdrawn PAS 1075.

Restriction: when applying the pipe bursting method to grey cast-iron pipes, the maximum operating pressure must be limited to max. 5 bar in SDR 11 pipes and max. 3.2 bar in SDR 17 pipes.

The product also fulfils the further requirements outlined in MUC-KSP-A 3030.

Product description:

HERKULES PE 100-RC

Co-extruded solid-wall pipes made of polyethylene PE 100-RC, for the following conditions of use and nominal diameters:

- Pipes made of polyethylene for alternative installation (Type 2)
- Nominal diameters: 75 to 500 mm
- SDR 17 and SDR 11

Production site:

Przedsiębiorstwo Skoplast S. i K.
 Szkopek sp. Jawna
 Kaczory ul. Raszkowska 9A
 63-430 ODOLANOW, POLAND

This certificate is valid to July 2023.
 Factory surveillance is carried out annually.

Munich, 10 July 2020

TÜV SÜD Industrie Service GmbH
 Institute for Plastics


 i. A. Schweizer

